

DRIFTSRAPPORT

Månedsrapport December 2025

Føllenslev Vandværk

1/2



MÆNGDE

TOTAL INDVINDING	2464,92 m ³
Indvinding	2464,92 m ³
TOTAL UDPUMPNING	2426,21 m ³
Lavtrykszone	1288,67 m ³
Højtryks zone	1137,54 m ³
ANDET	2438,11 m ³
Boring 2	1162,20 m ³
Boring 3	1275,91 m ³

KWH FORBRUG



ELMÅLER	1764 kWh
kWh Måler	1764 kWh



NATFORBRUG UDPUMPNING

UDPUMPNING

Vandforbrug mellem klokken 02.00 og 04.00

4.00 m³

3.00 m³

2.00 m³

1.00 m³

0.00 m³

01-12-2025
02-12-2025
03-12-2025
04-12-2025
05-12-2025
06-12-2025
07-12-2025
08-12-2025
09-12-2025
10-12-2025
11-12-2025
12-12-2025
13-12-2025
14-12-2025
15-12-2025
16-12-2025
17-12-2025
18-12-2025
19-12-2025
20-12-2025
21-12-2025
22-12-2025
23-12-2025
24-12-2025
25-12-2025
26-12-2025
27-12-2025
28-12-2025
29-12-2025
30-12-2025
31-12-2025
01-01-2026



FILTRE

FILTERSKYL	19
Filter 1	15
Filter 2	4

NØGLETAL



FLOWMÅLER

Minimum	0,70 m ³
	25-12-25 04:00->05:00
Maximum	6,93 m ³
	26-12-25 11:00->12:00
Gennemsnit	3,26 m ³ /h

EFFEKTIVITET

kWh-forbrug	1,38 m ³ /kWh
-------------	--------------------------



Blue Control®
BC7000

DRIFTSRAPPORT

Månedsrapport December 2025

Føllenslev Vandværk

2/2



DRIFTTIMER

INDVINDING




● Boring 2	5d 08t 38m
● Boring 3	6d 06t 15m

UDPUMPNING

● Pumpe 1	15d 19t 02m
● Pumpe 2	16d 00t 18m
● Pumpe 3	18d 05t 54m
● Pumpe 4	18d 10t 15m

ANDET

● Skyllpumpe	02t 43m
--------------	---------



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING
Boring 2	-4,78 m	-6,96 m	2,18 m
Boring 3	-4,32 m	-6,64 m	2,32 m



TÆLLERSTAND

31-12-2025 23:59:59

Boring 2	97255852 m ³ /h
Boring 3	104569 m ³ /h
Indvinding	412320 m ³ /h
Lavtrykszone	1235632 m ³
Højtryks zone	152568 m ³
kWh Måler	3045453 m ³



Blue Control®
BC7000